

**UNITED STATES OF AMERICA  
BEFORE THE  
FEDERAL ENERGY REGULATORY COMMISSION**

ANR Pipeline Company ) Docket No. RP16 - \_\_\_\_-000

**Summary of Prepared Direct Testimony of Patrick R. Crowley**

Mr. Crowley is employed by Brown, Williams, Moorhead and Quinn, Inc., a nationally recognized energy consulting firm, as a depreciation expert in regulated oil and natural gas pipelines. He provides Prepared Direct Testimony in this proceeding on behalf of ANR Pipeline Company (“ANR”) regarding the proper and adequate depreciation rates for ANR’s facilities based on reasonable remaining life estimates and a broad group straight line average remaining life depreciation methodology.

Mr. Crowley explains the concepts behind depreciation analysis and survivor curve theory, which establish the average service lives of the assets of the utility, the retirement decline curve, and the interim retirements that set the average remaining life for each account. Mr. Crowley then factors in the truncating factors that further limit the average remaining lives of ANR facilities and then calculates the depreciation rate. Mr. Crowley also calculates negative salvage rates for ANR’s assets. Using the retirements forecast from the survivor curves and the terminal retirement engineering study performed by ANR witness Taylor, Mr. Crowley calculates a negative salvage rate that composites near-term and long-term negative salvage.

Docket No. RP16-\_\_\_\_-000

Exhibit No. ANR-057

**UNITED STATES OF AMERICA  
BEFORE THE  
FEDERAL ENERGY REGULATORY COMMISSION**

ANR Pipeline Company

)

Docket No. RP16 - \_\_\_\_-000

**PREPARED DIRECT TESTIMONY  
OF PATRICK R. CROWLEY ON BEHALF OF  
ANR PIPELINE COMPANY**

January 29, 2016

## Table of Contents

### Prepared Direct Testimony

|      |                                      |    |
|------|--------------------------------------|----|
| I.   | INTRODUCTION                         | 1  |
| II.  | DEPRECIATION THEORY                  | 4  |
| III. | SURVIVOR CURVE THEORY                | 23 |
| IV.  | SIMULATED PLANT RECORD ANALYSIS      | 34 |
| V.   | REMAINING LIVES & DEPRECIATION RATES | 37 |
| VI.  | NEGATIVE SALVAGE                     | 52 |

### Workpapers

#### **Exhibit No. ANR-059          Depreciation Rate Derivations**

|             |  |
|-------------|--|
| Sch. No. 1  | Depreciation Rate Summary              |
| Sch. No. 2  | Depreciation Overview                  |
| Sch. No. 2A | Composite Plant Balances               |
| Sch. No. 3  | Parameters                             |
| Sch. No. 4  | Maintenance & Capacity Additions       |
| Sch. No. 5  | Depreciation Expense & Rate Derivation |
| Sch. No. 6  | Storage TNS by FERC Account            |
| Sch. No. 7  | Transmission TNS by FERC Account       |
| Sch. No. 8  | Intangible Plant Composite Rate        |
| Sch. No. 9  | Turbine Compressor Life Expectancy     |

#### **Exhibit No. ANR-060          Storage Survivor Curves**

|              |             |  |
|--------------|-------------|--|
| Sch. No. A-1 | Account 350 | Storage Rights of Way                    |
| Sch. No. A-2 | Account 351 | Storage Structures & Improvements        |
| Sch. No. A-3 | Account 352 | Storage Wells, Leaseholds, & Reservoirs  |
| Sch. No. A-4 | Account 353 | Storage Lines                            |
| Sch. No. A-5 | Account 354 | Storage Compressor Station Equipment     |
| Sch. No. A-6 | Account 355 | Storage Measuring & Regulating Equipment |
| Sch. No. A-7 | Account 356 | Storage Purification Equipment           |

#### **Exhibit No. ANR-061          Transmission Survivor Curves**

|              |             |   |
|--------------|-------------|---|
| Sch. No. B-1 | Account 365 | Transmission Rights of Way                    |
| Sch. No. B-2 | Account 366 | Transmission Structures & improvements        |
| Sch. No. B-3 | Account 367 | Transmission Mains                            |
| Sch. No. B-4 | Account 368 | Transmission Compressor Station Equipment     |
| Sch. No. B-5 | Account 369 | Transmission Measuring & Regulating Equipment |

**Glossary of Terms**

|         |  |
|---------|--|
| ALJ     | Administrative Law Judge                             |
| ANR     | ANR Pipeline Company                                 |
| ARL     | Average Remaining Life                               |
| ASL     | Average Service Life                                 |
| BLS     | Bureau of Labor Statistics                           |
| BWMQ    | Brown Williams Moorhead & Quinn, Inc.                |
| CI      | Conformance Index                                    |
| DEPR    | Depreciation   |
| FASB    | Financial Accounting Standards Board                 |
| FERC    | Federal Energy Regulatory Commission                 |
| INS     | Interim Negative Salvage                             |
| L Curve | Left Modal Iowa Survivor Curve                       |
| NBV     | Net Book Value                                       |
| NGA     | Natural Gas Act                                      |
| NS      | Negative Salvage                                     |
| PHMSA   | Pipeline & Hazardous Materials Safety Administration |
| PPI     | Producer Price Index                                 |
| R Curve | Right Modal Iowa Survivor Curve                      |
| S Curve | Symmetrical Modal Iowa Survivor Curve                |
| SPR     | Simulated Plant Record                               |
| TNS     | Terminal Negative Salvage                            |

**UNITED STATES OF AMERICA  
BEFORE THE  
FEDERAL ENERGY REGULATORY COMMISSION**

ANR Pipeline Company )

Docket No. RP16 - \_\_\_-000

**Prepared Direct Testimony of Patrick R. Crowley**

1 **I. INTRODUCTION**

2 **Q. Please state your name, occupation and business address.**

3 A. My name is Patrick R. Crowley and my business address is 1155 15<sup>th</sup> Street, NW, Suite  
4 1004 Washington, DC 20005. I am Vice President of Brown Williams Moorhead &  
5 Quinn, Inc. (“BWMQ”), an energy consulting firm in Washington DC.

6 **Q. On whose behalf are you submitting testimony in this proceeding?**

7 A. I am submitting testimony on behalf of ANR Pipeline Company (“ANR”).

8 **Q. What is the purpose of your direct testimony?**

9 A. The purpose of this Prepared Direct Testimony is to present my recommendation  
10 regarding the proper and adequate depreciation rates based on appropriate remaining life  
11 factors applicable to the ANR natural gas pipeline system. I am also recommending  
12 negative salvage rates for ANR’s storage and transmission functions that are a composite  
13 of the short and long-term negative salvage expectations.

14 **Q. Please state your professional experience and qualifications.**

15 A. I graduated from DePaul University in Chicago, Illinois with a Bachelor of Arts degree in  
16 economics in 1976 and a Master of Arts degree in economics in 1978, with a  
17 concentration in mathematical economics. Upon graduation from DePaul University in  
18 1978, I joined the Chicago, Rock Island & Pacific Railroad Company for a short time

1 working in the general manager's office before I joined the Federal Energy Regulatory  
2 Commission ("FERC" or "Commission") in 1979. I was employed at FERC for 28 years.  
3 For 24 of those 28 years, I was employed in the litigation division of the Office of  
4 Pipeline and Producer Regulation and its successor offices. I retired to form my own  
5 consulting firm, Crowley Energy Consulting, in February 2007, where I provided energy  
6 litigation support for clients in the natural gas and oil pipeline industries. I joined  
7 BWMQ in 2013.

8 My work as an Industry Economist in the Depreciation Branch of the Pipeline  
9 Rates Division of the Office of Pipeline and Producer Regulation at the FERC was  
10 mainly as an expert witness with the Trial Staff gas and oil litigation team from 1979 to  
11 1992. I prepared pipeline depreciation studies, long-term forecasts of crude oil and  
12 natural gas reserves and production, mortality studies of plant retirements, and cost  
13 behavior studies for pipeline facilities. From 1992 through 1994, I worked on the  
14 operational aspects of the Order No. 636 service restructuring of Texas Eastern  
15 Transmission, LP and was the FERC Staff team leader for the restructuring of Tennessee  
16 Gas Pipeline Company. From 1994 through 1998, I worked on the advisory side of the  
17 Commission where I prepared reports for Commission orders regarding proposals for  
18 revised tariff terms, new services, rate designs, and tariff rates, as well as a wide variety  
19 of utility reports and cost studies. In 1998, I returned to the litigation side of the  
20 Commission where I worked on electric utility, natural gas, and oil pipeline rate cases,  
21 complaint cases, and show cause orders until I retired.

22 **Q. Have you testified before the Federal Energy Regulatory Commission?**

23 A. I filed testimony before FERC in numerous dockets, as reflected on Exhibit No. ANR-  
24 058.

1 **Q. Have you provided testimony specifically on depreciation?**

2 A. Yes I have, as reflected in the list of cases in Exhibit No. ANR-058.

3 **Q. Have you provided any exhibits with your testimony?**

4 A. Yes. I have included the following exhibits with my testimony:

5 Exhibit No. ANR-058 *Curriculum Vitae* of Patrick R. Crowley

6 Exhibit No. ANR-059 Depreciation Workpapers

7 Exhibit No. ANR-060 Storage Survivor Curve Analysis

8 Exhibit No. ANR-061 Transmission Survivor Curves Analysis

9 **Q. What materials are included in your Exhibit No. ANR-059?**

10 A. Exhibit No. ANR-059 is made up of the workpapers supporting my depreciation and  
11 negative salvage rate recommendations for the ANR pipeline system. The schedules  
12 present each step of the process of developing the proper and adequate depreciation rates  
13 given ANR's current operations and the recovery of its investment in plant over the  
14 remaining useful life of those assets. The following schedules are included in Exhibit  
15 No. ANR-059:

16 Schedule No. 1 Current & Recommended Depreciation Rates

17 Schedule No. 2 Depreciation Overview

18 Schedule No. 2A Composite Plant Balances

19 Schedule No. 3 Model Parameters

20 Schedule No. 4 Maintenance & Capacity Plant Additions

21 Schedule No. 5 Depreciation Expense & Rate Derivation

22 Schedule No. 6 Storage Negative Salvage Rate

23 Schedule No. 7 Transmission Negative Salvage Rate

1                    Schedule No. 8            Intangible Plant Composite Rate

2                    Schedule No. 9            Turbine Compressors Life Expectancy

3    **Q.    What materials are included in your Exhibit Nos. ANR-060 and ANR-061?**

4    A.    Exhibit Nos. ANR-060 and ANR-061 are made up of the survivor curve analysis  
5           workpapers for each of the major property accounts. Exhibit No. ANR-060 consists of  
6           Schedule Nos. A-1 through A-7 which include the storage function accounts. Exhibit No.  
7           ANR-061 consists of Schedule Nos. B-1 through B-5 which include the transmission  
8           function accounts.

9    **Q.    Will you summarize your recommendation in this case?**

10   A.    Yes. Provided below is a summary of ANR's current depreciation rates along with the  
11           rates I support in this testimony:

|  | <u>Current Rates</u> | <u>Proposed Rates</u> |
|--|----------------------|-----------------------|
| <b><u>Depreciation Rates</u></b>         |                      |                       |
| Intangible Plant                         | various              | 10.78%                |
| Production & Gathering                   | 0.00%                | 0.49%                 |
| Underground Storage                      | 2.30%                | 1.91%                 |
| Transmission Plant                       | 1.30%                | 3.18%                 |
| Acct 370 Comm Eq                         | 8.50%                | 10.00%                |
| General Plant                            | various              |                       |
| Acct. 390 Structures & Improvements      |                      | 5.5%                  |
| Acct. 391 Office Furniture & Equipment   |                      | 16.2%                 |
| Acct. 392 Transportation Equipment       |                      | 9.8%                  |
| Acct. 394 Tools, Shop & Garage Equipment |                      | 10.8%                 |
| Acct. 396 Power Operated Equipment       |                      | 3.8%                  |



|   |                                |       |       |
|---|--------------------------------|-------|-------|
| 1 | <b><u>Negative Salvage</u></b> |       |       |
| 2 | Underground Storage            | 0.00% | 0.70% |
| 3 | Transmission                   | 0.00% | 1.46% |

4 **Q. How were ANR's current depreciation rates developed?**

5 A. ANR's current depreciation rates are the result of a settlement of ANR's last rate case in  
6 Docket No. RP94-43-000 – which occurred 20 years ago.

## II. DEPRECIATION THEORY

1  
2 **Q. Please describe depreciation theory.**

3 A. Depreciation is a term used in accounting, economics, and finance to convey the concept  
4 of the inherent loss of value in an entity's capital assets over time and the associated  
5 allocation of that loss in capital value over some defined period. Capital costs are those  
6 costs incurred to acquire plant and equipment that will be used over several accounting  
7 periods to facilitate the provision of an entity's goods and services. The anticipated  
8 longevity of the asset is, in a sense, the purchase of future services from the asset;  
9 depreciation is the expensing of those future services. When investors purchase assets  
10 they expect to get their money back and earn a profit on that investment: the return *of*  
11 investment as well as return *on* the investment. In order to get an accurate assessment of  
12 their economic activities, entities need to accurately match expenses with the revenue  
13 generated. Deducting the costs of operations and the capital investment costs from the  
14 revenue stream helps reveal the profitability of the enterprise. Depreciation and  
15 amortization are the means by which capital costs are allocated over time to reflect the  
16 concept that capital costs contribute to profitability in all periods. This concept is simply  
17 that capital costs are recovered over the economic life span of the assets. The Maximum  
18 physical life of the asset is expected to be in general 200% of the average service life, but  
19 the economic life can be substantially shorter than the physical life. The recovery of the  
20 capital costs must occur within the economic lifespan of the asset. The tools used in  
21 depreciation analysis are the foundation for allocating capital costs over the useful life of  
22 a depreciable asset to provide investors the opportunity to recoup their investment in a  
23 reasonable and consistent manner during the expected service life of the asset.

1 **Q. How does the Commission define depreciation?**

2 A. The Commission defines depreciation as:

3 [T]he loss in service value not restored by current maintenance, incurred  
4 in connection with the consumption or prospective retirement of gas plant  
5 in the course of service from causes which are known to be in current  
6 operation and against which the utility is not protected by insurance.  
7 Among the causes to be given consideration are wear and tear, decay,  
8 action of the elements, inadequacy, obsolescence, changes in the art,  
9 changes in the demand and requirements of public authorities, and in the  
10 case of natural gas companies, the exhaustion of natural resources.  
11 18 C.F.R. Part 201, Definitions, 12.B (2015).

12 **Q. What does “loss in service value” mean?**

13 A. Loss in service value is the diminishment of the ability of an asset to provide useful  
14 service to the utility. Loss in service value occurs broadly from two sources: physical  
15 causes such as wear and tear, decay, and action of the elements, and, second, what can be  
16 classified as economic causes (inadequacy, technological or economic obsolescence,  
17 changes in the art, changes in demand, requirements of public authorities, and the  
18 exhaustion of natural resources).

19 **Q. How has FERC historically viewed the supply-side economic life of natural gas  
20 pipelines?**

21 A. The primary factor that FERC historically relied upon in determining a pipeline’s  
22 economic life in NGA section 4 and 7 proceedings is the potential exhaustion of natural  
23 gas resources. In 1990, FERC stated it “normally based the depreciation rates of major  
24 interstate pipelines on economic, or useful, lives that are between 20 and 25 years.”  
25 *Iroquois Gas Transmission System, L.P.*, 52 FERC ¶ 61,091 at 61,392-93 (1990). FERC  
26 extended the economic life to 35 years in 1998 in *Iroquois Gas Transmission System,  
27 L.P.*, 84 FERC ¶ 61,086 (1998) (“*Iroquois*”). In *Iroquois*, FERC explained:

1 The economic factors the Commission's regulations require relate to  
2 "changes in demand," "exhaustion of the supply of natural resources" and,  
3 to some extent, "requirements of public authorities." The Commission  
4 finds that the ALJ has adequately addressed these factors. As discussed  
5 below, the ALJ relied on evidence presented by Joint Parties, Staff, and  
6 the Public Service Commission of New York which showed that demand  
7 for gas is increasing in the Northeast, the market served by Iroquois, and  
8 that the natural gas supply, which the ALJ found is the single most  
9 important factor in determining a pipeline's remaining useful life, is over  
10 35 years.

11 *Iroquois* at p. 61,438.

12 It is important to note that the FERC acknowledged in *Iroquois* that while natural gas  
13 supply may exist for "over 35 years" the remaining economic life actually adopted by the  
14 Commission was, in fact, 35 years. Since *Iroquois*, the FERC has not approved an  
15 economic life over 35 years in a litigated proceeding.

16 The Commission in *Portland Natural Gas Transmission Sys.*, 134 FERC ¶ 61,129  
17 (2011) at P 127 noted:

18 The ALJ rejected [Portland Shippers Group's] recommended end-life of  
19 40 years for Portland's System, finding it extended beyond the  
20 Commission's standard of 35 years, and is inconsistent with Commission  
21 precedent indicating that reserve estimate projected beyond 35 years are  
22 speculative.

23 The Commission affirmed the Administrative Law Judge's ("ALJ") rejection of the  
24 Portland Shippers Group's and Staff's recommended economic end-life beyond 35 years.

25 **Q. How has the demand-side economic life for pipelines generally been determined?**

26 A. In the past, Commission's primary focus for determining a pipeline's depreciable life, as  
27 noted above, was the estimated gas reserves at the upstream end of its system. Demand  
28 for the pipeline's services at the other end of the system was assumed to be endless.  
29 However, a pipeline with abundant gas supplies available at its upstream end but no  
30 demand at the other end will not be transporting any gas. The upheaval in the pipeline

1 industry over the last few years has led me to conclude that long-term demand stability is  
2 less certain than once thought.

3 **Q. What causes long-term demand to be less certain than in the past?**

4 A. For almost 70 years the pipeline industry has, in general, built larger and safer pipeline  
5 systems to bring natural gas and oil products from the Louisiana, Texas, and Gulf Coast  
6 production areas to the Midwest and northeast United States consuming areas. More  
7 recently, developments in drilling technology have made natural gas supplies trapped in  
8 shale formations economically feasible to produce. The traditional resource basins have  
9 been overshadowed by newly accessible resource basins that are closer to consuming  
10 areas, such as the Marcellus and Utica shales. While the demand for natural gas in  
11 general has grown substantially, the demand for transportation service from any one  
12 pipeline in particular can no longer be assumed to be endless. Customers are avoiding  
13 long-term contracting in order to take advantage of alternative market opportunities.

14 **Q. Is pipeline infrastructure changing in response to demand conditions?**

15 A. Yes. There are a number of pipelines connected to traditional supply basins that have  
16 seen demand for transportation of supplies from their traditional supply basins fall off in  
17 response to the availability of competitively-priced shale resources in the eastern United  
18 States or the abundance of liquids produced from shale deposits. One fallout of the  
19 decrease in demand for supplies from traditional supply basins is a decrease in utilization  
20 of the pipeline facilities that access those basins. Another consequence has been, as an  
21 example, for pipelines to reverse the flow of certain segments of pipe so that supplies  
22 from the Marcellus and Utica shales physically can reach markets that, prior to these  
23 recent developments, were served by natural gas from the traditional supply basins.

1 **Q. How do physical conditions affect depreciation rates?**

2 A. Oil and gas pipeline systems are built to safely transport hydrocarbons for many years.  
3 Properly maintained, all pipeline assets have very long life expectancies. However, what  
4 goes into the ground as a state-of-the-art industrial asset will, one day, run up against  
5 various factors that will cause the asset to be retired. First, simple usage takes its toll on  
6 any asset. Under normal usage, every asset has a range of service life expectancy that  
7 will define its maximum depreciable life. But various factors can shorten that  
8 expectation, such as extreme weather-related damage, third-party damage, or  
9 governmental regulations. These often bring an immediate end to the facilities' useful  
10 life. Other factors, as indicated by the FERC definition above, can shorten a life  
11 expectation not because the asset itself fails but because changes in technology,  
12 methodology, or regulations render the asset obsolete. Improvements in safety,  
13 efficiency, or usefulness can lead to the retirement/replacement of assets that might  
14 otherwise have remained in service for many years. Both FERC policy and depreciation  
15 theory allow for the truncation of the useful life of facilities based on these  
16 considerations.

17 **Q. How do the requirements of public authorities affect depreciation rates?**

18 A. The requirements of public authorities can have a significant impact on the depreciable  
19 life of facilities. A common example is the encroachment of human population upon  
20 previously remote areas, which may trigger a requirement to relocate a pipeline. Public  
21 authorities may require physical removal, replacement, or upgrade of plant or equipment.  
22 Public authorities may also establish operational criteria that impact the usefulness of  
23 some assets and may alter the useful life expectancy of those assets. The cost of

1 complying with the requirements of public authorities can cause the cost of using the  
2 facilities to become prohibitive and thus render the facilities economically obsolete.  
3 Such actions must be taken into consideration in setting depreciation rates when those  
4 requirements cause the truncation of the useful life of pipeline assets.

5 **Q. How does the natural resource base affect depreciation rates?**

6 A. The determination of the useful life of industrial property is often dependent upon an  
7 underlying non-renewable natural resource base, the exhaustion of which sets the outer  
8 limits of the assets' depreciable lives. In the case of oil and natural gas properties, the  
9 useful life of some assets is limited to the economic life of the oil or natural gas  
10 anticipated to flow through the assets, including "proved reserves" known to be  
11 accessible at any given time, plus the "future reserves" that can be reasonably expected to  
12 become proved reserves at some point. On the other hand, evolving market forces can  
13 make gas supplies that were previously economic no longer economic in a relatively  
14 short time period. For example, the rapid development of shale gas resources in the  
15 Marcellus, Utica, Bakken, and Eagle Ford shale plays have radically altered the status  
16 quo of conventional U.S. natural gas production and even other dry shale gas plays, such  
17 as the Haynesville. The impact of these changes can also dramatically change gas flows  
18 across the U.S. natural gas pipeline infrastructure. Competition among suppliers,  
19 transporters, and marketers has placed new and powerful business risk burdens on many  
20 players in the industry. Depreciation analysis must take into consideration these  
21 economic forces that threaten the longevity of the useful life of existing infrastructure  
22 assets.

23 **Q. What are interim retirements and how do they affect depreciation rates?**

1 A. Interim retirements are the routine retirements of plant and equipment that will occur  
2 each year between the study date and the terminal closing of the pipeline system. The  
3 importance of interim retirements, for depreciation study purposes, is that such  
4 retirements shorten the *average* depreciable life of the assets. If some units are retired  
5 prior to the end of the planned service life, the associated depreciation accruals will not  
6 have fully recovered the invested cost in the assets. Depreciation rates must capture the  
7 average life expectancy of the assets in the accounts, which is estimated through the  
8 survivor curve analysis of interim retirements. This is more fully explained in the  
9 survivor curve discussion later in this testimony.

10 **Q. Based on the factors you have discussed, what economic life have you selected for**  
11 **ANR's facilities?**

12 A. While strong-supply side arguments can be made for expanded economic life spans,  
13 equally strong demand-side arguments can support significantly shorter economic life  
14 spans for specific pipeline systems. Long-term forecasting becomes more and more  
15 speculative the further out the forecast. As discussed in the testimony of ANR witness  
16 Kirk, it is reasonable to assume natural gas will be available for at least 35 years, the  
17 timeframe traditionally used by FERC to assess natural gas supply. In the absence of a  
18 strong indicator for some other economic life, I have elected to maintain the  
19 Commission's traditional 35-year life estimate for ANR's facilities.

20 **Q. Do you believe that using an economic life greater than 35 years is speculative?**

21 A. Yes, I do. Although national natural gas supplies are abundant, the response of the  
22 natural gas industry has demonstrated that the demand for the services of any given  
23 pipeline is not secured merely by the regional gas supplies to which it is physically  
24 connected. Competition from even distant natural gas supply basins can bring about



1 quick and powerful shifts in demand. In just the last five years many south-to-north  
2 pipelines connected to long-term gas supplies on their south ends have sought to change  
3 the direction of their systems in response to the newly discovered abundant and less  
4 expensive resources in the north. Where “long-term” was once thought of as over 30  
5 years, it would now appear that in some circumstances “long-term” is about five years –  
6 the time it takes for infrastructure to respond to changes in demand.

7 **Q. Have you relied on any other witnesses for your recommendation of a 35-year**  
8 **economic life for ANR?**

9 A. Yes. ANR witness Kirk has conducted and is sponsoring a study of the natural gas  
10 reserves available to the ANR system. I have relied on his analysis and study in  
11 formulating my recommendation.

12 **Q. What depreciation methodology did you use for ANR?**

13 A. I used the broad group, straight line, average remaining life method of depreciation.  
14 Under this method, which is the standard method for FERC-regulated pipelines, all of the  
15 assets within a group are considered to be homogeneous units of plant used and treated  
16 alike across the system regardless of the vintage, construction techniques, or retirement  
17 rate. In practice, there are two levels of grouping – by FERC account and by function.  
18 Generally all assets within a FERC account are considered as one group and a  
19 depreciation *expense* is derived. Then the FERC accounts are combined into a larger  
20 functional group, such as storage or transmission, with one depreciation *rate* for the  
21 whole function. Where operational considerations warrant, assets within a given FERC  
22 account are grouped in a different function, such as offshore transmission versus onshore  
23 transmission, to reflect the distinctive use and depreciable life expectations for those

1 assets. I also used a whole life rate for general plant, which I will explain later in this  
2 testimony.

3 **Q. What are the different concepts regarding life expectations for industrial property?**

4 A. The depreciable lives of a gas pipeline entity's assets are bound by three life expectancy  
5 estimates: 1) the average physical service life expectancy of the various classes of  
6 property; 2) the estimated remaining life of the natural gas reserves supporting the need  
7 for the assets; and 3) the estimated remaining economic life of the demand for services  
8 provided by the capital assets. These three factors set the stage for calculating the average  
9 remaining depreciable life, which also takes into account the truncation date and interim  
10 retirements. The service life measures the physical life expectancy of the plant in service,  
11 absent specific economic or resource limitations. The remaining life of the resource base  
12 measures the expectations for the exhaustion of natural resources and its impact of the  
13 assets in question. The remaining economic life is the life expectancy as impacted by  
14 economic forces such as changes in regulations, alternative transportation routes, or  
15 alternative energy sources. The average remaining depreciable life takes all these factors  
16 into consideration to select a life span for use in the depreciation calculations.

17 **Q. Does the age of the assets make a difference?**

18 A. Yes, it does. The estimation of future retirements is accomplished by multiplying the  
19 decline curve ratios found in the survivor curve times the plant balance. But recall that  
20 the survivor curve reflects the survivorship ratio for each age interval so that determining  
21 the retirement curve would require a matrix of multiplications to calculate the  
22 survivorship of each age interval dollar for each transaction year out into the future until  
23 the plant is exhausted, which could be two or three hundred years of calculations for each  
24 vintage.

1           Alternatively, the stream of retirements can be approximated by calculating the  
2 average age of the plant and multiplying the total plant installations by the survivor curve  
3 surviving percentage at the average age and each successive year for the time period  
4 selected for the study (truncation date). The sum of the surviving plant balances divided  
5 by the full installations reveals the average remaining life. For example, if the average  
6 age (as a percent of average service life) is 10 years old, the chances are that the  
7 survivorship percentage is still in the 97+% range. In other words, the plant is young and  
8 few retirements will be forecast for many years to come because the decline curve is still  
9 rather flat for the relevant period. On the other hand, if the average age is older, say 50  
10 years (as a percent of the ASL), the plant is much further along the survivor curve  
11 trajectory and the forecast for retirements would be much higher because the decline  
12 curve is much steeper for the relevant period. These survivorship forecasts determine the  
13 surviving plant balances for the future, and in turn, the average remaining life of the  
14 surviving dollars. Consequently, the average age of the plant is critical to setting the  
15 depreciation rate.

16 **Q. How is the average age determined?**

17 A. Traditionally, the average age is determined by multiplying the surviving dollars invested  
18 per year by the age of those dollars, and then dividing by the total dollar amount invested.  
19 The result is the average age of the dollars in the account.

20 **Q. Is there an inherent problem measuring the average age in dollars rather than**  
21 **physical plant?**

22 A. Yes, there can be. Survivor curve methodology analyzes the age of retirements not the  
23 value of the retirements and relies on the assumption that the units of measurements it  
24 uses are comparable. The wear and tear experienced by a 15-year-old pipe in the 1960s

1 should be the same as wear and tear experienced by a 15-year-old pipe in the 1990s,  
2 given the same quality of material, throughput, maintenance, and other externals. The  
3 cost of the pipe should have no effect on the wear and tear of the assets. But because the  
4 data used for survivor curve analysis is dollars rather than physical measurements, the  
5 units of retirement can become un-comparable. For example, \$1,000,000 of 1960s-era  
6 line pipe would represent approximately 10 miles of pipe, whereas \$1,000,000 of 2015  
7 line pipe would barely cover half-a-mile. Consequently, a forecast of future  
8 retirements/survivorship based on the average age of inflation impacted dollars will skew  
9 toward a much higher survivorship position on the survivor curve and underestimate the  
10 retirement rate going forward – and in turn overestimate the average remaining life and  
11 underestimate the appropriate depreciation rate.

12 **Q. How can you correct for the distortion?**

13 A. The distortion in the value of the assets over time caused by inflation can be corrected by  
14 applying a deflator index to the time series in developing the average age. By applying  
15 the Bureau of Labor Statistics (“BLS”) Producer Price Index (“PPI”) for steel mill  
16 products to the original cost plant activity data, the dollars from all vintages are put on  
17 the same playing field. Now we have 1960 dollars that are comparable to 1990 dollars,  
18 and so on. The physical plant represented by \$1,000,000 should be roughly the same for  
19 all vintages. Yet because the age of the dollars has not changed, the survivor curve  
20 results are the same as before the indexing. The difference is that the average age of the  
21 plant is calculated based on indexed values rather than inflation impacted dollars. The  
22 indexed average age can then be used for the survivor curve application, resulting in a  
23 retirements forecast more in line with the actual experience of the plant.

1 **Q. Describe the concept of truncation.**

2 A. Most pipelines incorporate a truncation date in their derivations of depreciation rates to  
3 reflect the fact that the average actual useful lifespan of the assets is often significantly  
4 shorter than the physical average service life. The incorporation of a truncation date is  
5 often unrelated to the physical characteristics of the asset itself but due to reasons such as  
6 the loss of reserves supporting its use, technical obsolescence bringing about  
7 replacement, or the requirements of public authorities that may lead to economic  
8 obsolescence of certain facilities. The truncation may cause the remaining life of the  
9 assets to be less than the average physical life.

10 **Q. Describe the methodological steps you took to develop the depreciation rates for**  
11 **ANR.**

12 A. The calculation of depreciation rates involves several steps that focus on the actual life  
13 expectancy of the plant in service and derive an accrual rate that should match the return  
14 of investment capital with the actual useful lives of the property. These steps are to:

- 15 1. determine the depreciable plant to be recovered;
- 16 2. estimate near-term plant additions;
- 17 3. examine retirement patterns by account;
- 18 4. use a survivor curve model to estimate average service lives;
- 19 5. estimate the remaining useful life of natural resources;
- 20 6. assess the long-term demand for the pipeline services;
- 21 7. set the truncation date;
- 22 8. calculate the average remaining lives by account; and
- 23 9. calculate the depreciation rates.

24 **Q. Your Schedule No. 4 of Depreciation Workpapers Exhibit No. ANR-059 indicates**  
25 **the addition of both near-term maintenance capital and capacity capital in deriving**

1 **the depreciation base. What do these groupings mean and why have you added**  
2 **near-term additions to the depreciable rate base?**

- 3 A. The depreciation rates are likely to be in effect for some time before the next rate case  
4 and the plant will grow somewhat during that period. Just as future plant retirements are  
5 taken into consideration in developing the depreciation rates, so too should plant  
6 additions be forecast so that the depreciation rates can recover the investment over its  
7 useful life span. I separated maintenance capital from capacity capital to reflect the  
8 inherent difference between additions needed to continue providing the current level of  
9 service and the additions needed to expand services to new customers or new contracts.

10 ANR witness Hampton discusses the need and planning for capital additions to  
11 upgrade ANR's aging system over the next three years. Specifically, he notes the need to  
12 upgrade ANR's compressor units, associated compressor station, system communications  
13 and control equipment, and metering and regulation equipment. His discussions  
14 regarding the age of ANR's system are echoed in the graphs of plant growth in my  
15 Exhibit No. ANR-061 at pages 3, 9, 15, 21, and 27. These graphs show the annual plant  
16 additions and retirements for each transmission property account in original cost dollars  
17 and inflation adjusted dollars. As discussed further elsewhere, the inflationary impact on  
18 time series data tends to minimize past period amounts when, in fact, after adjusting for  
19 inflation, the past period investments carry much greater weight. Adjusting the  
20 investment time series for inflation illustrates that a large proportion of ANR's physical  
21 system is over 50-years old. As ANR witness Hampton notes, ensuring the safety and  
22 reliability of the system dictates that replacing much of this aging plant is a prudent  
23 action that should begin over the next few years. But for every million dollars in 1950s-  
24 era plant retired, the replacement cost will be almost \$10 million. Those replacement

1 investments cannot begin recovery unless they are incorporated into the depreciation rate.  
2 Hence, I have incorporated near-term plant additions into the development of the  
3 depreciation rates to recover the investment that will be in place during the pendency of  
4 the rates developed in this rate case.

5 The forecast amounts for near-term plant additions were provided by ANR. The  
6 anticipated additions are shown on Schedule No. 4 of Exhibit No. ANR-059.

7 **Q. Some would argue that your use of near-term plant additions is speculative and**  
8 **should not be included in the derivation of depreciation rates. Do you agree?**

9 A. No, I do not agree. ANR has a history of transmission function plant additions in all  
10 major accounts going back 64 years. It is not speculative to assume the pipeline will  
11 continue to engage in capital maintenance replacements, install upgraded equipment,  
12 expand service capacity, and respond to safety improvements. These near-term additions  
13 can be estimated by looking to current capital budget forecasts or looking back to recent  
14 actual plant activity. In either case the estimate of near-term additions reflects the actual  
15 needs of the pipeline system and is the best estimate of plant balances most likely to be in  
16 place during the pendency of the tariff rates being developed. It is known that there will  
17 be plant additions and those additions are measurable.

18 **Q. In 1992, the Commission rejected the use of plant additions in developing**  
19 **depreciation rates in a specific rate filing. How is this case different?**

20 A. The Commission's decision in *Indiana & Michigan Municipal Distributors Ass'n v*  
21 *Indiana Michigan Power Co.*, 59 FERC ¶ 61,260 at 61,968, addressed a proposal that  
22 incorporated 17 years of plant additions (1992 through 2009). I too would question 17  
23 years of plant additions. My testimony, to the contrary, deals with very near-term plant  
24 additions with an eye toward estimating the average plant balance that will be in effect

1 while the depreciation rates and tariff rates are in effect. The near-term additions are  
2 easily estimated and therefore are a readily known number.

3 **Q. The Code of Federal Regulations does not mention future plant in defining**  
4 **depreciation practices. Why should near-term additions be included in the**  
5 **depreciation rate derivation?**

6 A. Depreciation rate development is often seen as a snapshot of plant in service at the end of  
7 the test period. My approach is more holistic in that I developed depreciation rates that  
8 cover the reasonable range of time over which the tariff rates and embedded depreciation  
9 rates will be in effect. The plant in service will continuously expand and contract as  
10 upgrades replace old technology, larger facilities replace smaller, exhausted plant is  
11 retired and new customers are connected to the system. Plant in service should be seen in  
12 the context of the evolution of the pipeline's attempts to respond to market needs, new  
13 technology, and operational efficiencies. The average plant in service over the period  
14 that the rates will be in effect should be the guiding figure in developing the depreciation  
15 rates.


16 **Q. Is the concept of near-term plant balances alien to current depreciation theory and**  
17 **practice?**

18 A. No, it is not. The concept of using the average plant balance is inherent in the use of  
19 survivor curves to develop the average remaining life. It is a long-accepted depreciation  
20 concept that the depreciation rate must be calculated on the basis of the average plant  
21 balance over the remaining life of the assets to ensure the proper rate of recovery of the  
22 plant investment. The decline curve derived via the survivor curve analysis generates an  
23 average plant balance for each year of the interim period between the study date and the  
24 termination date. As illustrated in Graph No. 1, the decline in the average plant balance  
25 results in the under-recovery of depreciation, shown as an orange line/area above the



1 decline curve, if the average plant balance is not incorporated into the depreciation rate  
 2 calculation. The composite of the average balances weighted by the years that plant will  
 3 be in use produces the average remaining life and in turn the depreciation rate. So the  
 4 concept of incorporating changes in the near-term average plant balance is not alien to  
 5 standard depreciation accounting, it is indeed central to depreciation theory.

6 **Graph No. 1 – Average Plant Balance & Depreciation Recovery**



7  
 8 **Q. How have you organized the near-term additions?**

9 A. Plant additions are necessary to maintain the pipeline system's safety and integrity, and to  
 10 capture efficiencies in updated technology and performance. Additions are also often  
 11 needed to expand capacity to serve new customers. For an older system like ANR,  
 12 capital additions undertaken for system maintenance become more important as the older  
 13 plant reaches its average service life and gets retired. As noted in the discussions on  
 14 Accounts 367 Mains and 368 Compressor Station Equipment below, ANR has a

1 significant level of pipe and compression equipment that is 50 years old or older and  
2 facing retirement in the near future. While the dollar value of the older plant is far below  
3 today's inflated cost for similar plant and equipment, the older plant represents a large  
4 proportion of the actual physical plant. As noted earlier, a mile of line pipe in the 1950s  
5 cost just a tenth of what that same mile might cost today. The forecasts of near-term  
6 retirements indicated by the survivor curve analysis assume an average age for the plant.  
7 Because actual retirements are likely to be older plant and thus less valuable dollars, an  
8 inflation adjusted retirement forecast will correctly include significantly more of the older  
9 physical plant than if a standard non-inflation adjusted dollar average age is used.  
10 Replacing that older, lower cost, plant will burden ANR with much higher replacement  
11 costs to maintain the system at its current capacity. Consequently, I have differentiated  
12 near-term additions between maintenance capital and capital projections that are aimed at  
13 system expansion.


### III. SURVIVOR CURVE THEORY

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23

**Q. What is a survivor curve?**

A. A survivor curve is the pictorial end result of an actuarial analysis of hundreds of thousands of transactions that make up the ‘life story’ of industrial property accounts. With each passing year the retirements of property, if any, leave a smaller percentage of the original installation in place. If retirements were uniform in size and regularity, a simple straight line projection would provide an adequate forecast of future retirements, and, in turn, allow the calculation of the average remaining life of the assets. But the retirement patterns of industrial property do not follow a straight line. The retirement patterns of industrial property are characterized by a complex life trajectory which includes a transition point where survivorship takes a dramatic downward turn. The retirement rate and survivorship rate are inversely related phenomena. The upside down bell curve shape of retirement frequency distribution creates the ski-slope shape survivorship curve. After a period of substantial retirements, the retirement pattern passes through another transition point where retirements fall off, leaving a long tail of lingering survivorship. The overall lifespan survivorship trajectory for most industrial property follows this ski-slope pattern seen in Graph No. 2 that, despite an appearance of simplicity, requires complex mathematical formulae to replicate. Adding to the complexity, additions to plant, transfers between accounts, and various adjustments to plant accounts over time, can obscure the patterns of retirements, making it difficult to discern the physical life expectancy of plant and equipment. Survivor curve analysis translates the hundreds of thousands of data points into recognizable patterns, enabling an analysis and forecast of future life expectancies.

1 **Graph No. 2 – Survivor Curve of Original Data**



2

3 **Q. How does survivor curve theory work?**

4 A. The survivor curve analysis primarily deals with two survivor curves: one being a curve  
 5 that traces the actual surviving dollars from each vintage of plant addition and the other a  
 6 prototypical Iowa Curve selected to carry the trend of the actual data out into the future  
 7 for forecasting purposes. Once the original data is synthesized into an original experience  
 8 survival curve (see Graph No. 2 above), the curve is compared to hundreds of  
 9 prototypical curves (see Graph Nos. 3 and 4 below) to find one that will best forecast the  
 10 most likely experience of future interim retirements. With the retirement forecast in  
 11 hand, the average remaining life can be calculated.

12 **Q. Is survivor curve theory accepted by the Commission?**

13 A. Yes, the Commission has approved depreciation rates based on survivor curve theory for  
 14 over 40 years.

1 **Q. How do these retirement characteristics convert into survivor curves?**

2 A. While the retirements of property are the drivers of actuarial studies, it is the surviving  
3 dollars that are of concern. For each installation year investment, the percent of that  
4 year's plant still surviving in each subsequent year is calculated. The same exercise is  
5 performed for every year's installation dollars. Once the string of aged retirements is  
6 assembled, summation of surviving aged plant and aged retirements reveals the actual  
7 experienced survival for the account, which when plotted becomes the survivor curve for  
8 that specific account as illustrated in Graph No. 2.

9 **Q. How does the survivor curve of the actual data support forecasts of future**  
10 **retirements?**


11 A. Once the original survivor curve is obtained, the question turns to what should be  
12 expected of that account in terms of future retirements. For this aspect of the study we  
13 look to prototype curves that mimic the pattern of our original account activity. The  
14 retirement ratios that characterize the curves are applied to the surviving plant in service  
15 to generate interim retirement dollars. While there are a few options for typical curve  
16 patterns, the Iowa Type Survivor curves are the most commonly used for depreciation  
17 purposes and are the curves used for this study.

18 **Q. What are Iowa Curves?**

19 A. Iowa Curves represent standardized retirement patterns of industrial property developed  
20 from actuarial studies conducted in the 1930s. The Iowa Curves consist of families of  
21 curves that reflect left-modal, symmetrical-modal, and right-modal frequency  
22 distributions, called simply L, S, and R curves. Each family of curves includes four to  
23 five curve sets within the family, labeled  $R_1$ ,  $R_2$ ,  $R_3$ , and so on, each with slightly  
24 different slope configurations (see Graph No. 3 below). Further, each curve has


1 representatives from each average service life age group from 5 years to 120 years. The  
2 modality of the curves simply reflect whether the most frequently occurring retirement  
3 age is younger than the average retirement age – an L Curve (i.e., to the left of the  
4 average service life on a graph) or older than the average retirement age – an R Curve  
5 (i.e., to the right of the average service life), or equal to the average retirement age – an S  
6 Curve (i.e., symmetrical to the average service life). Graph No. 3 also illustrates the wide  
7 variety of retirement patterns that can occur within each family of curves, from plant that  
8 experiences retirements almost immediately after installation (as in the  $R_1$  type curve) to  
9 plant that may go a very long time before any significant retirements take place (as in the  
10  $R_5$  type curve). Graph No. 4 illustrates the impact of different curves on the percent  
11 surviving at the termination date, which affects the derivation of the average remaining  
12 life, which in turn sets the depreciation rate.

1 **Graph No. 3 – R Family of Iowa Curves**



2

3 **Graph No. 4 – Comparison of Curves**




4

5 **Q. How does the model select the “best fit” curve?**

1 A. The selection of a curve is done by a combination of statistical comparison and informed  
 2 knowledge of the nature of the assets. The statistical assessment is a simple calculation  
 3 of the differences between the original data and the selected Iowa Curve. The differences  
 4 are squared to eliminate positive and negative differences from cancelling each other out  
 5 as well as to accentuate deviations. The curve with the least sum of squared difference  
 6 between the actual book value of the account and the predicted value of the account is  
 7 generally the best fitting curve and, unless some other factor weighs heavily in the  
 8 analysis, that curve will be used to forecast future retirements. This concept is illustrated  
 9 in Graph No. 5.

10 **Graph No. 5 – Iowa Curves Represent the Original Data**



11

12 **Q. Why would you not use the curve identified by the model as the “best fit” curve?**

13 A. The Iowa Curve with the least sum of squared differences may fit the overall pattern of  
 14 the original survivor curve but may not fit the portion of the original life curve  
 15 representing the interim period. For depreciation purposes, the interim period between




1 the study date and the termination date defines the period over which the remaining  
2 undepreciated plant investment must be recovered. To determine the average remaining  
3 life of the assets over that period, we take the average age of the plant in service,  
4 converting it to age as a percent of average service life to determine where along the Iowa  
5 survivor curve it sits. The retirement rate from that point on is the most likely retirement  
6 pattern that will define the average remaining life of the asset. The survivor curve model  
7 calculates the least squares statistical test for each of several hundred curves. However,  
8 of equal weight is the analyst's assessment of the individual property type and patterns of  
9 retirements.

10 **Q. Describe the concept of the average service life.**

11 A. The physical plant of large industrial entities like pipelines is made up of thousands of  
12 units of property. For example, the pipeline itself is not one long pipe. Rather, it consists  
13 of thousands of sections of pipe of various lengths installed over decades as the system  
14 expanded, or as portions of the system were replaced due to damage or wear and tear.  
15 While the usefulness and longevity of each section of pipe depends on the conditions  
16 associated with its use, eventually the retirement experience begins to reveal how long an  
17 average section of pipe can be expected to remain in service, as illustrated in Graph No. 6  
18 below.

1 **Graph No. 6 - Average Service Life Derivation**



2  
3 At some point assets begin to drop out of service so that some plant has shorter lives than  
4 others. The average is derived by calculating the percent surviving at each age interval,  
5 summing the surviving dollars, and dividing by the original balance. See Graph No. 6.  
6 For our purposes, knowing the average service life (“ASL”) of plant and equipment  
7 allows for an accommodation in the depreciation rate derivation to reflect that some plant  
8 retires over the years, causing a decline in the depreciation base and a possible shortfall in  
9 capital recovery as illustrated in Graph No. 1 earlier. Once a prototypical curve is  
10 selected to represent the anticipated retirement patterns, an ASL can be calculated for the  
11 property account.

12 **Q. Why is the ASL important?**


13 A. In general, depreciation rates recover the cost of the plant over its life expectancy. The  
14 application of a straight line depreciation rate to the annual rate base builds the  
15 depreciation reserves through annual accruals in equal installments, as shown in the

1 vertical bars above. By the truncation date the plant should be fully depreciated.  
2 However, if the rate base is declining because of interim retirements, the annual accruals  
3 will not add up to the full amount needed for recovery by the truncation date, leaving a  
4 shortfall. The importance of using survivor curves is that by using them, we can avoid  
5 under-recovery of depreciation due to interim retirements between the study date and the  
6 termination date. Interim retirements are considered fully recovered and the full original  
7 cost of the unit of property is deducted from the accumulated reserve for depreciation. If  
8 interim retirements are not taken into consideration in deriving the average remaining life  
9 of plant, the depreciation rate will have under-recovered the plant at the truncation date,  
10 as illustrated by Graph No. 1 earlier.

11 **Q. Describe the concept of the average remaining life.**

12 A. The average remaining life (“ARL”) calculation is restricted to the time between the  
13 study date and the termination date. The ARL, commonly known as the “area under the  
14 curve” as illustrated in Graph No. 7 below, represents the time period over which the  
15 company’s remaining net plant will be depreciated. Dividing the sum of the surviving  
16 balances as calculated by the survivor curve by the starting balance provides the ARL,  
17 which is used in the depreciation calculations.

1

**Graph No. 7 - Average Remaining Life & Area Under the Curve**

2

3 **Q. How does the age of the assets in an account affect the depreciation rate?**

4 A. Industrial property retirements exhibit a pattern in the distribution of aged retirements  
 5 resembling an upside down bell-shaped. The number of retirements of young plant is  
 6 low but retirements grow over time to crest at the highest level, which corresponds to the  
 7 average service life, and then taper off with some older plant lasting out to the future.  
 8 The corollary to the bell curve is the ski-slope shaped survivor curve. When the  
 9 retirement curve is subtracted from the original installations, the result is the survivorship  
 10 curve. The life span of line pipe assets is characterized by three main phases: first, a long  
 11 period of very low retirements that creates a high level plateau of survivors; second, a  
 12 period of increasing retirement frequency, which creates the primary slope of the survivor  
 13 curve; and third, a leveling off of retirements at the end of the life span, which creates a

1 long flat tail of survivors. This general pattern is represented in the survivor curves  
2 shown in Graph No. 3 above.

3 The rate of plant retirements will depend on where along the curve the average  
4 plant is located. The average age of the plant in service will indicate, in general, the level  
5 of retirements to be expected over the course of the remaining life of the asset. Line pipe  
6 that, on average, is 65 years old will have a significantly different retirement rate than  
7 line pipe that is 5 years old. The metallurgical differences in materials and changes in  
8 construction techniques contribute to variation in life expectancies for both the whole life  
9 span of the assets and the near-term expectations given the current respective average  
10 ages of the plant. It is important to note, as I did earlier, that the survivor curve is  
11 measuring the age of the dollars retired, not the value of the dollars retired. Adjusting the  
12 time series for inflation will approximate the age of the plant for retirement purposes  
13 rather than the age of the dollars.

#### IV. SIMULATED PLANT RECORD ANALYSIS

1  
2 **Q. The actuarial survivor curve model you described requires vintaged retirement, i.e.,**  
3 **retirement data tied to the year of installation of the assets. What happens if the**  
4 **vintaged data is not available?**

5 A. In the absence of reliable data tying the annual retirements back to the specific year of  
6 installation, the Simulated Plant Record Model can provide a similar forecast of annual  
7 retirements for depreciation rate purposes. The Simulated Plant Record (“SPR”) model  
8 relies on the survivor curve theories for its foundation but does not generate a least  
9 squares analysis for each data point. Instead, the SPR model applies a prototype Iowa  
10 Curve to each annual plant addition and calculates a final balance for the account,  
11 assuming the plant has retired in a pattern similar to that of the Iowa Curves. The  
12 selected curve is used to forecast future retirements, which provides the average  
13 remaining life and ultimately the depreciation rate.

14 **Q. Does ANR have vintaged plant retirement data?**

15 A. No, ANR does not have vintaged retirement data. Consequently, I used the SPR model to  
16 simulate the retirement patterns from each plant addition to see which curve came closest  
17 to generating an ending balance that matches the actual book balance for each account.

18 **Q. How does the SPR Model represent the actual plant activity?**

19 A. As plant ages, the surviving plant ratio falls as it moves along and down the survivor  
20 curve. The average age of the plant in each account determines where the account is, vis-  
21 à-vis the survivor curve, at the study date. The SPR method calculates a theoretical  
22 retirement trajectory that it applies to each vintage of additions. The curve that best  
23 forecasts an ending plant balance closest to the actual plant balance is deemed, generally,  
24 to be the best representative pattern for all vintages. That declining survival ratio

1 determines the interim retirements expected to take place between the study date and the  
 2 terminal date. These retirements, in turn, are the foundation for determining the average  
 3 remaining life and the negative salvage estimate.

4 **Q. Is there a goodness of fit measurement to gauge the accuracy of the model?**

5 A. Yes there is a goodness of fit measurement – the Conformance Index (“CI”). The CI is  
 6 derived by dividing the actual ending balance by the absolute value of the difference  
 7 between the actual ending and the predicted ending balance.

$$8 \quad \frac{\text{Actual ending value}}{9 \quad | \text{Predicted ending value} - \text{Actual ending value} |}$$

10 The predicted ending value is squared to eliminate negative numbers and then the square  
 11 root is taken to hold the predicted value as close to the actual value as possible. If the  
 12 difference between the predicted and actual ending balances is high, then the CI ratio will  
 13 be low. Conversely, if the difference between the predicted and actual ending balances  
 14 is low, then the CI ratio will be high. The rule of thumb for ranking CIs is:

|    |          |               |
|----|----------|---------------|
| 15 | Over 75  | excellent fit |
| 16 | 50 to 75 | good fit      |
| 17 | 15 to 50 | fair fit      |
| 18 | Under 25 | poor fit      |

19 The rationale for the CI valuation is that in order for the CI to reach 75, the difference  
 20 between the actual and predicted balances must be within 1.5% of the actual balance. A  
 21 CI of 50 indicates a differential of only 2%. This ranking system thus requires the  
 22 forecasted values to fall close to the actual values to be considered even a “fair” fitting of  
 23 a hypothetical Iowa Survivor curve to the actual data. A CI above 100 indicates a  
 24 forecast fit that is within 1% of the actual data; larger values for the CI over 100 do not  
 25 indicate a significantly better fitting curve. If more than one curve has a CI beyond 100,

1           the analyst incorporates other factors to select an appropriate curve. As the difference  
2           between the predicted ending balance and the actual ending balance gets smaller, the CI  
3           value increases. As the difference approaches zero, the CI approaches infinity.



1                   **V.       REMAINING LIVES & DEPRECIATION RATES**

2   **Q.       How did you determine the average remaining lives for each property account?**

3   A.       The BWMQ Simulated Plant Record model estimates the average service life on the basis  
4           of the Iowa-type Survivor Curve that calculates an ending balance that most closely  
5           matches the FERC Form 2 book balance at the close of the study date period. Using the  
6           best fit Iowa Curve, the annual surviving plant balance is calculated via the survivor  
7           curve decline rate (at the approximate inflation adjusted average age of the surviving  
8           plant) multiplied by the total net additions for the account. Then the annual balances are  
9           summed and divided by the beginning balance to arrive at the average remaining life  
10          estimate.

11 **Q.       What data did you use to develop the service life estimates?**

12 A.       The plant data is drawn from the FERC Annual Report FERC Form 2 and comes in the  
13          form of annual additions, retirements, transfers and adjustments.

14 **Q.       What adjustments did you make to accommodate for the inflationary distortions in  
15          the data series discussed earlier?**

16 A.       As noted earlier, a long-term time series can become distorted by the cumulative impact  
17          of inflation such that the data at each end of the data series are no longer compatible.  
18          1950s-era dollars bought more plant and equipment than do current dollars. ANR's  
19          transmission plant data stretch over 64 years, which if left unadjusted, leaves  
20          incomparable units of measure for the ANR plant addition and retirement activities.  
21          Plant retirements, as shown in the FERC Form 2, are likely to be older invested dollars  
22          (ie., more physical material) rather than newer invested dollars. I adjusted for this  
23          distortion by applying the BLS deflator series, PPI for steel mill products, to the plant  
24          activity data series. Applying the deflator index equalizes the vintage year activities so

1 that 1950s-era additions and retirements carry the same weight as 2000s-era plant  
2 activities in developing the average remaining life of the accounts. The deflator index is  
3 used to develop only the average age of each account in the transmission function. The  
4 data used for developing the survivor curves themselves remained the original cost  
5 dollars.

6 **Q. Describe the schedules included in Exhibit Nos. ANR-060 and ANR-061.**

7 A. Exhibit Nos. ANR-060 and ANR-061 are the schedules that reflect the data, survivor  
8 curves, and retirement rates for each of the major accounts in the Storage and  
9 Transmission functions. Each schedule has six pages. Page 1 contains a) the survivor  
10 curve, b) a description of the data and its value, and c) a summary of the pertinent  
11 statistics for the account. Page 2 has graphs that present the plant data over time, in both  
12 original cost dollars and indexed dollars for transmission plant. Pages 3 and 4 includes  
13 the historical data of plant additions, retirements, transfers, and adjustments. Page 5  
14 presents the forecast of interim retirements based on the curve and the concluding  
15 average remaining life figure. Page 6 reproduces the relevant portion of the Conformance  
16 Index from the model for the curves considered for the account.

17 **Intangible Plant**

18 **Q. Describe your assessment of Account 301 Intangible Organization.**

19 A. Account 301 includes \$4,395 in organizations costs incurred in 1949, which appear to be  
20 the cost of incorporation. These costs are not treated as depreciable.

21 **Q. Describe your assessment of Account 303 Intangible Miscellaneous.**

22 A. Account 303 includes the cost of computer software, measurement software, computer  
23 equipment, and other intangible assets that serve a company-wide function. The  
24 Intangible Plant is composed of group software assets for which the book depreciation

1 rate is based on the term of the service contract. Each year some contracts expire and  
2 new software contracts of varying terms are engaged. The composite average remaining  
3 life for the Intangible Plant is 1.85 years, with an associated depreciation rate of 10.78%  
4 (as applied to the gross plant for the whole function). The groups and the associated  
5 depreciation rates are shown in Schedule No. 8 of Exhibit No. ANR-059, page 19 of 20.

## 6 **Production & Gathering Plant**

### 7 **Q. Describe your assessment of Account 325 Gathering Rights of Way.**

8 A. Account 325 includes the cost of rights of way for production and gathering facilities.  
9 The average age of the plant is 46 years old. I applied the same average remaining life  
10 expectancy as I used for Transmission Plant Rights of Way: 30.4 years.

### 11 **Q. Describe your assessment of Account 328 Field Measuring & Regulating Station** 12 **Structures.**

13 A. Account 328 includes the cost of sheds, structures, and property improvements used to  
14 support gathering and production operations. The average age is 40 years old. I applied  
15 the same average remaining life expectancy as I used for Transmission Plant Structures &  
16 Improvements: 29.8 years.

### 17 **Q. Describe your assessment of Account 329 Gathering Other Structures.**

18 A. Account 329 includes two expenses for property improvements. The average age is 7  
19 years old. I applied the same average remaining life expectancy as I used for  
20 Transmission Plant Structures & Improvements: 29.8 years.

### 21 **Q. Describe your assessment of Account 332 Gathering Field Lines.**

22 A. Account 332 includes of small diameter lateral pipe lines connection field operations to  
23 the mainline system. The average age is 43 years old. I applied the same average  
24 remaining life expectancy as I used for Transmission Plant Mains: 30.3 years.

1 **Q. Describe your assessment of Account 334 Gathering Field Measuring & Regulating**  
2 **Equipment.**

3 A. Account 334 includes the cost of equipment such as meters, piping, controls, and  
4 dehydrators. The average age is 26 years old. I applied the same average remaining life  
5 expectancy as I used for Transmission Plant Measuring equipment: 30.1 years.

## 6 **Storage Plant**

7 **Q. Describe your assessment of Account 350.2 Storage Rights of Way.**

8 A. Account 350.2 includes the costs of rights-of-way agreements acquired for utility  
9 operations. The data for this account covers 1967 through 2014. ANR's Storage Rights-  
10 of-Way account has not seen significant expansion for most of its history with the  
11 exception of three years - 1980, 2003, and 2010. The history shows few retirements, with  
12 one large retirement in 2009 representing over 16% of the existing plant balance. The  
13 inflation adjusted average age of the account is 27.5 years. The four best curves, as  
14 judged by the Conformance Index, suggest an average physical life of between 55 and 65  
15 years with average remaining lives of between 25 and 30 years. The  $L_2$ ,  $S_0$ , and  $S_1$  curves  
16 follow a similar trajectory while the  $R_1$  takes a dramatic decline in the out-years of the  
17 truncation period. I selected the 65  $S_0$  curve because of the goodness of fit measurement.  
18 Using this curve forecasts interim retirements that, in turn, produce an average remaining  
19 life of 24.4 years over the 35 year economic life. See Exhibit No. ANR-060, Schedule  
20 No. A-1.

21 **Q. Describe your assessment of Account 351 Storage Structures & Improvements.**

22 A. Account 351 includes the buildings, garages, access roads, fencing, garage doors,  
23 cabinets, lighting systems, sheds, and other housing material in which storage operating  
24 equipment is housed, as well as improvements to the structures over time. The inflation

1 adjusted average age of the account is 28.4 years. ANR's Storage Structures &  
2 Improvements account had a very long period of plant additions with almost no  
3 retirements from 1970 through 2000. There was a cluster of large retirements from 2000  
4 to 2007 but they were minor in comparison to the total balance. I elected to use the 60-  
5 S<sub>0</sub> Iowa Curve, which has the highest Conformance Index. The 60-S<sub>0</sub> Curve produces an  
6 average remaining life of 30.61 years over the remaining economic life of 35 years. See  
7 Exhibit No. ANR-060, Schedule No. A-2.

8 **Q. Describe your assessment of Account 352 Storage Wells, Leaseholds, & Reservoirs.**

9 A. Account 352 is made up of three subaccounts: 352.0 Wells, 352.1 Leaseholds, and 352.2  
10 Reservoirs. The inflation adjusted average age of the account is 31.5 years. The account  
11 includes the costs of drilling wells, Christmas trees, deeds and leases, and mineral rights.  
12 In this account there are a number of large retirements that are somewhat clustered  
13 around 1986 and 2006. The Conformance Index for the 50-R<sub>2</sub> curve indicates a good  
14 match with the original data and produces an average remaining life of 29.1 years over  
15 the remaining economic life of 35 years. See Exhibit No. ANR-060, Schedule No. A-3.

16 **Q. Describe your assessment of Account 353 Storage Lines.**

17 A. Account 353 includes the cost of line pipe, valves, fittings, and line pack. The inflation  
18 adjusted average age of the account is 31.5 years. The average age of the plant is 23 years  
19 old. Account 353 has a 45-year history of regular annual plant additions but almost no  
20 retirements until 2000 and thereafter. Despite the unbalanced retirement experience, the  
21 50-S<sub>1</sub> curve has a high Conformance Index, suggesting a good match with the original  
22 data pointing toward a good indicator of future interim retirements. Using the 50-S<sub>1</sub>  
23 curve forecasts interim retirements that produce an average remaining life of 28.7 years

1 over the remaining economic life of 35 years. See Exhibit No. ANR-060, Schedule No.  
2 A-4.

3 **Q. Describe your assessment of Account 354 Storage Compressor Station Equipment.**

4 A. Account 354 includes the cost of compressors, control valves, mufflers, lubricating oils,  
5 fire suppression systems, and other equipment needed to operate the stations that move  
6 gas through the system. The inflation adjusted average age of the account is 25.7 years.  
7 Account 354 has a 45-year history of large plant additions and few retirements until 2000  
8 and thereafter. The survivor curve model indicates a wide range of ASLs in the range 40  
9 to 70 years. However, consistent with the discussion below regarding transmission  
10 function compressor station equipment, I set the ARL for Account 354 at 10 years. See  
11 Exhibit No. ANR-060, Schedule No. A-5.

12 **Q. Describe your assessment of Account 355 Storage Measuring & Regulating**  
13 **Equipment.**

14 A. Account 355 includes the costs of equipment needed to manage the gas flows, such as  
15 plug and ball valves, hygrometers, gravimeters, chromatographs, manifolds, control  
16 software, and other equipment. The inflation adjusted average age of the account is 32.4  
17 years. Account 355 has few retirements until the 2000s and modest retirements since that  
18 time, with an exception in 2003 when a major retirement took place. The survivor curves  
19 indicate an average service life in 50- to 55-year range. The CI for the 50-R<sub>1</sub> curve  
20 indicates a good match with the original data and should provide the good indicator of  
21 future interim retirements; it produces an average remaining life of 24.7 years over the  
22 remaining economic life of 35 years. See Exhibit No. ANR-060, Schedule No. A-6.

23 **Q. Describe your assessment of Account 356 Storage Purification Equipment.**

1 A. Account 356 includes the scrubbers and dehydrators, and similar equipment used to clean  
2 the gas stream. The Account has no retirements until a 2004 major retirement. The  
3 inflation adjusted average age of the account is 29.7 years. The lack of retirement data  
4 cautions against relying on any specific survivor curve. Nonetheless, the 65-S<sub>0</sub> Iowa  
5 Curve indicates a good match with the original data and forecasts interim retirements that  
6 in turn produce an average remaining life of 28.4 years over the remaining economic life  
7 of 35 years. See Exhibit No. ANR-060, Schedule No. A-7.

8 **Q. Describe your assessment of Account 357 Other Equipment.**

9 A. Account 357 includes parts and equipment that don't quite fit into other property  
10 accounts. The inflation adjusted average age of the account is 31.5 years. There was  
11 insufficient data to run an SPR model so I elected to use the same average remaining life  
12 as the purification equipment account due to the similar nature of the assets within the  
13 accounts.

#### 14 **Transmission Plant**

15 **Q. Describe your assessment of Account 365.2 Transmission Rights of Way.**

16 A. Account 365.2 Transmission Rights of Way includes the cost of acquiring the rights to  
17 use property for pipeline operations. The average age of the original cost dollars in the  
18 account is 28 years old, the inflation adjusted average age is 46.8 years. The account has  
19 had modest retirements throughout its history. The indexed net additions graph and  
20 indexed retirement graphs reproduced on page 2 of Section B-1 reflect the relative weight  
21 of the early dollars investments. I selected the 80-R<sub>5</sub> Iowa Curve because it has a high  
22 Conformance Index and its forecast of a 5-year average of near-term interim retirements  
23 is close the actual recent 5-year average retirement level. Using the 80-R<sub>5</sub> curve

1 forecasts interim retirements that in turn produce an average remaining life of 30.4 years  
2 over the remaining economic life of 35 years. See Exhibit No. ANR-061, Schedule No.  
3 B-1.

4 **Q. Describe your assessment of Account 366 Transmission Structures &**  
5 **Improvements.**

6 A. Account 366 Transmission Structures & Improvements is the account that holds the costs  
7 associated with the buildings, garages, and landscape improvements that host the  
8 equipment needed to operate the system. The indexed net additions and indexed  
9 retirements charts on page 2 of Schedule B-2 indicate the relative impact of the adjusted  
10 earl plant activity in 1951 and 1966. These adjustments shift the average age of the  
11 account from 29 years old in original cost dollars to 52.8 years old in inflation adjusted  
12 dollars. The survivor curve model indicates average service lives in the 65- to 90-year  
13 range. I selected the 85-R<sub>5</sub> Iowa Curve because it has a high Conformance Index and its  
14 five-year average for interim retirements is reflective of the actual five-year average.  
15 Using the 85-R<sub>5</sub> curve forecasts interim retirements that produce an average remaining  
16 life of 29.8 years over the remaining economic life of 35 years. See Exhibit No. ANR-  
17 061, Schedule No. B-2.

18 **Q. Describe your assessment of Account 367 Transmission Mains.**

19 A. Account 367 Transmission Mains is broken into two subgroups: the Tie Line Integrity  
20 program facilities and Mains. The division recognizes ANR's commitment to pipeline  
21 safety and integrity in its capital plan to retire and replace the Tie Line that links ANR's  
22 Southwest and Southeast Mainlines. Certain Tie Line facilities are line pipe  
23 manufactured by Youngstown Steel Works that are known to have structural integrity  
24 problems. Although ANR has not had any such problems on its own system, it plans, out



1 of an abundance of caution, to retire and replace these sections of line pipe over the next  
2 five years. Consequently, I have assigned the approximately \$25 million in Youngstown  
3 Tie Line pipe a 5 year average remaining life. The balance of the Mains account is  
4 discussed below.

5 Account 367 holds the costs associated with building the line pipe itself as well as  
6 the river crossings, line pack, valves, hauling, and inspections. Account 367 has a robust  
7 history of plant additions and retirements going back 64 years. It started with a \$75  
8 million balance, expanded by \$100 million in the late 1950s, and then experienced a  
9 prolonged period of expansion through to the present with \$20 to \$60 million added per  
10 year. When the inflation index is applied to the data series, as shown on page 2 of  
11 Schedule B-3, the relative import of additions in 1951 and 1966 become clear, shifting  
12 the average age from 32 years old to 49.2 years old. Relative to additions, the annual  
13 retirements appear to have been modest until the 2000s when retirements began to top  
14 several million every year. But the inflation adjusted series indicates a more robust  
15 retirement history in the 1960s/1970s. The relative size of the retirements over the long  
16 run results in a survivor curve that indicates a possibly a long lived asset. There are  
17 several Iowa Curves that pass the threshold tests for goodness of fit with average service  
18 lives ranging from 70 to 90 years old. I selected the 85-R<sub>4</sub> Iowa Curve because the five  
19 average of its near-term retirement forecast results in a figure closer to the five year  
20 average of recent pipeline experience. Using this curve and ASL results in a 30.3-year  
21 average remaining life over the 35-year economic life. See Exhibit No. ANR-061,  
22 Schedule No. B-3.

23 **Q. Describe Account 368 Transmission Compressor Station Equipment.**

1 A. Account 368 Transmission Compressor Station Equipment is made up of the compressor  
2 engines that pressurize natural gas to push it through the pipeline system, and the  
3 associated pipes, meters, control valves, platforms, and exhaust handlers. ANR has  
4 approximately 308 compressor units at 58 compressor stations across its system, most of  
5 which are powered by reciprocating engines and 37 are powered by gas turbines. The  
6 mix of compressor units includes some that are scheduled for abandonment in the near  
7 future, some with low annual run rates, some with high annual run rates, some that run  
8 day and night, and some that are used on a stand-by basis. Although only 10% of the  
9 compressors are turbines, the turbines make up 30% of the compressor station equipment  
10 account dollars.

11 The data on compressor plant addition and retirement dollars reflects that some  
12 current plant goes back to the early 1950s, if not further (See Schedule No. B-4 in Exhibit  
13 No. ANR-061. The Retirements graph shows that ANR had very low retirement events,  
14 as reflected in the original cost dollars in this account for the first three decades, followed  
15 by modest retirements in the 1980s and 1990s. But the inflation adjusted net additions  
16 and retirement charts show a somewhat more intense retirement history and a much more  
17 intense net additions summary. Then in the 2000s, after decades of little to no retirement  
18 activity, ANR experienced enormous turnover in Account 368 as millions of dollars of  
19 plant and equipment was retired. The inflation adjusted data series shifts the average age  
20 from 15 years old to 33 years old.

21 **Q. What does the survivor curve model suggest regarding Account 368?**

22 A. The SPR model indicates a 60-R<sub>5</sub> and a 65-S<sub>1</sub> are the best fitting curves, indicating an  
23 ASL of 60 to 75 years, and a 27- and 30-year average remaining life, respectively,  
24 assuming the 35-year economic truncation life. ANR's Account 368 data (see the

1 Retirements graph and Plant Balance graph in Schedule No. B-4 of Exhibit No. ANR-061  
2 reflects a long history of low retirement activity from 1951 to the 2000s. The model  
3 forecast a 60 year ASL and a 27 year ARL.

4 **Q. Do you concur with the survivor curve projection for Account 368?**

5 A. No, I do not. In reviewing the data and talking to several ANR system managers, I have  
6 come to the conclusion that the 30-year ARL projection for Account 368 no longer fits  
7 the situation facing the account. The ongoing changes in how ANR uses compression  
8 equipment, as well as its ongoing work to modernize its compressor equipment, dictates a  
9 different approach. The survivor curve theory can only predict the future based on the  
10 mathematical trends inherent in the data. In this instance, the ANR compressor station  
11 equipment is not going to follow its historical path. The mix of station equipment and  
12 maintenance and modernization policies suggest a much shorter life span than the 30-  
13 some year average remaining life predicted by the survivor curve methodology.

14 **Q. What average remaining life do you recommend for Account 368?**

15 A. I developed separate rates for turbines and reciprocating engine equipment as reflected in  
16 Schedule No. 5 and then composited the impacts to derive the overall rate.

17 Turbines

18 Gas turbine engines are significantly more efficient than reciprocating engines but that  
19 efficiency comes at a cost – the turbines are both more expensive to acquire and have a  
20 shorter life expectancy. Turbine manufacturers recommend major overhauls at intervals  
21 of 35,000 to 40,000 hours, roughly every four to four-and-a-half years assuming the  
22 engine ran 24/7 for the year (8,740 hours). The substantial overhauling cost is  
23 capitalized, in effect, like purchasing a new turbine. The effective depreciable lifespan of  
24 a turbine engine is thus the time between overhauls. While ANR has some turbine

1 equipment that is much older than ten years, the industry standard, in my experience, is  
2 that turbines have useful lives between major overhauls of less than ten years. In ANR's  
3 case, the most recent turbine usage data reflect the low throughput levels of the 2012 –  
4 2015 period. On average, ANR's 37 turbine engines ran 1,311 hours per year, which  
5 suggests a 26.3-year lifespan (combined 34,500 average overhaul hour recommendation  
6 divided by 1,311 hours). Given that the average age of ANR's turbine assets is 15-years  
7 old, the average remaining life of ANR's turbine compressors is 11 years.

8 Recips

9 ANR has 223 reciprocating engine compressor units in the Transmission function. Some  
10 of the investment in plant associated with these engines date back to 1949. The average  
11 age of the dollars invested in ANR's recip engines is approximately 20 years old,  
12 although the indexed age is about 33 years old. As noted in the survivor curve discussion  
13 above, compressor station equipment can have average service lives into the 60 year  
14 range. However, as these machines approach the higher life expectancies, they require  
15 more frequent and more expensive maintenance regimens. The cost of major overhauls is  
16 capitalized just as it is for turbines. As noted by ANR witness Hampton, ANR's  
17 maintenance policy, given the age of the equipment, is to conduct a major overhaul on  
18 each recip engine every ten years. This, in effect, establishes a ten year lifespan for the  
19 capitalized overhaul costs for recip engine equipment. In addition, given a 35-year  
20 remaining economic life and plant that is at least 20 years old on average, 15 years would  
21 be a reasonable ARL estimate. Averaging the 10- and 15-year estimates suggests a 12.5  
22 year ARL for recip compression equipment.

23 **Q. Describe your assessment of Account 369 Transmission Measuring & Regulating**  
24 **Equipment.**

1 A. Account 369 Transmission Measuring & Regulating Equipment holds the costs of the  
2 meters, gauges, and minor piping needed to monitor and control the system. ANR has  
3 approximately 600 active metering facilities. The account has a lively history of annual  
4 plant additions and retirements. The indexed net additions and indexed retirements charts  
5 on page 2 of Schedule No. B-5 illustrate the relative impact of inflation adjusted plant  
6 activity in the 1960s and early 1970s, which shifts the average age from 15 years old to  
7 24.8 years old. I selected the 65-R<sub>1</sub> Iowa Curve because it has a high Conformance Index  
8 score and its five year average forecast retirements is close the most recent five year  
9 average for retirements. Using the 65-R<sub>1</sub> Curve results in an average remaining life of  
10 30.1 years over the 35-year economic remaining lifespan. See Exhibit No. ANR-061,  
11 Schedule No. B-5.

12 **Q. Describe your assessment of Account 370 Transmission Communications**  
13 **Equipment.**

14 A. Account 370 Transmission Communications Equipment holds the costs associated with  
15 the telephones, microwave equipment, towers, and receivers used to manage the system.  
16 Account 370 has had frequent retirements throughout its history but a tapering off in net  
17 additions of late. The account is currently almost fully accrued. Given that the nature  
18 of communications equipment is becoming more digital and wireless, and governed by  
19 software rather than hardware, I have elected to suggest a 10% depreciation rate as a  
20 placeholder rate pending new plant additions for communications upgrades. ANR uses a  
21 separate depreciation rate for Account 370 rather than joining the function wide  
22 depreciation rate.

23 **General Plant**

24 **Q. What were your conclusions regarding General Plant depreciation rates?**

1 A. The current depreciation rates for ANR's General Plant accounts are shown in column d  
2 of Exhibit No. ANR-059, Schedule No. 2; the recommended rates are shown in column f.  
3 This analysis gives weight to ANR's substantial capital improvement plans, as reflected  
4 in the plant additions shown in Exhibit No. ANR-059, Schedule No. 4. The calculations  
5 leading to the recommended depreciation rates are shown on Schedule No. 5 of Exhibit  
6 No. ANR-059.

7 Account 390 Structures & Improvements – Account 390 includes plant such as office  
8 space, shelving, phone systems, heating and plumbing improvements. The current  
9 depreciation rate is 1.30%. Unlike other structures and improvement accounts, Account  
10 390 does not include buildings themselves but rather the interior fittings; consequently, I  
11 recommend using a 20 year service life. Given the average age of approximately 2.8  
12 years, the average remaining life is then 17.2 years. Dividing the projected net plant by  
13 17.2 years, and then dividing by the gross plant in service, the resulting depreciation rate  
14 is 5.47%.

15 Account 391 Office Equipment – The current depreciation rates is 6.67%. I recommend  
16 using a 7-year average service life. Given the average age of approximately 2.7 years,  
17 the average remaining life is then 4.3 years. Dividing the projected net plant by 4.3  
18 years, and then dividing by the gross plant in service, the resulting depreciation rate is  
19 16.17%.

20 Account 392 Transportation Equipment – The current depreciation rate is 9.47%. I  
21 recommend using a 10-year service life. Given the average age of approximately 4.8  
22 years, the average remaining life is then 8 years. Dividing the projected net plant by 8

1 years, and then dividing by the gross plant in service, the resulting depreciation rate is  
2 9.79%.

3 Account 394 Tools, Shop, & Garage Equipment – The current depreciation rate is 5.71%.

4 I recommend using a 15-year service life. Given the average age of approximately 10.9  
5 years, the average remaining life is then 4.1 years. Dividing the projected net plant by  
6 4.1 years, and then dividing by the gross plant in service, the resulting depreciation rate is  
7 10.8%.

8 Account 396 Power Operated Equipment – The current depreciation rate is 5.71%. I

9 recommend using a 12-year service life and, given the average age of approximately 10.3  
10 years, the average remaining life is then 1.7 years. Dividing the projected net plant by  
11 1.7 years, and then dividing by the gross plant in service, the resulting depreciation rate is  
12 3.76%.

## VI. NEGATIVE SALVAGE

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23

**Q. What is negative salvage?**

A. Negative salvage is the cost of taking plant out of service. In many instances the cost is *de minimis* and treated as maintenance expense but in other instances substantial costs can be incurred. When these costs become sizable they are treated as part of the recovery of capital costs and debited to the accumulated reserve for depreciation. Similarly, the salvage value of assets removed from service represent a recovery of some of the cost of acquiring the asset and are thus also treated as part of the depreciation of capital costs, in this case a credit to the accumulated reserve for depreciation. Where the cost of removal exceeds the salvage value of the retired asset, the excess cost is termed net salvage or “negative salvage” and debited to the accumulated reserve for depreciation.

Companies incur negative salvage in two ways, first on the cost of removing interim retirements and second on the decommissioning, removal, and remediation upon the final termination of the company’s assets that remain at the end of the service life. While net salvage is often incorporated into the depreciation expense recovery for individual asset accounts, here a composite net salvage rate estimate for both interim negative salvage (“INS”) and terminal negative salvage (“TNS”) is computed for the transmission function.

**Q. Does ANR currently have negative salvage rates?**

A. No.

**Q. Do you recommend establishing negative salvage rates on ANR?**

A. Yes, I do. Although many ANR property accounts have a modest retirement history, the bulk of its plant is thirty or more years old, with some line pipe and metering equipment



1 approaching 50 years old. These facilities are going to start moving over the edge of the  
2 survivor curve decline horizon, after which we should see a much higher rate of plant  
3 retirements and associated negative salvage costs. These interim retirements are part of  
4 the plant balance forecast discussed above and are used to derive the average remaining  
5 life estimate. I would expect that ANR, like all other pipelines, will experience costs of  
6 removal that exceed salvage value of the scrap steel and meters. So a negative salvage  
7 expense should be anticipated and a negative salvage rate established to accommodate the  
8 anticipated costs.

9 **Q. How were the terminal negative salvage estimates derived?**

10 A. Upon reaching the end of the useful life of the pipeline assets, the facilities are either  
11 physically removed from the service area for disposal or made safe for abandonment in  
12 place. The cost of removal and remediation of retirements is based on the civil  
13 engineering study of the storage and transmission function plant done by ANR witness  
14 Taylor. Mr. Taylor's exhibits reflect the cost of removal and dismantling on a project by  
15 project basis. I have reformatted those costs by FERC property accounts, and calculated  
16 the negative salvage rates for the three plant accounts from which most of these costs will  
17 arise. His figure is incorporated into Schedule Nos. 6 and 7 of Exhibit No. ANR-059 for  
18 the development of composite net salvage rates.

19 **Q. How did you estimate the cost of interim retirements?**

20 A. I developed the interim retirement negative salvage expense by first pulling the plant to  
21 be retired from the survivor curve forecasts and then applying the negative salvage ratio  
22 by account as determined from the terminal negative salvage study performed by ANR  
23 witness Taylor. The TNS study is an engineering based study that examines

1 dismantlement costs for the entire system. The TNS study approaches cost by  
2 construction project, such as a river crossing or dismantling of a compressor station,  
3 rather than by FERC account numbers.

4 **Q. How did you composite the interim retirement cost estimates and the terminal**  
5 **retirement cost estimates?**

6 A. The composite process is shown on Schedule No. 7 for the Transmission function and  
7 Schedule No. 6 for the Storage function. Each schedule is in three parts: A) the  
8 Engineering Study, B) Applying the TNS Rate to Retirements, and C) Composite  
9 Negative Salvage Rate.

10 In part A, the methodology converts the TNS study cost estimates into FERC  
11 property accounts and converts them into a negative salvage rate in column f by dividing  
12 the negative salvage cost in e by the plant in service for that account in column b.  
13 Meanwhile, the gross plant in service from column b is separated into the interim  
14 retirements developed in the survivor curve analysis (column c) and the remainder of  
15 plant that will be subject to the terminal removal costs (column d).

16 In part B, the methodology applies the TNS rates (column f) to the interim  
17 retirements (column c) to develop the cost of removal for interim retirements in column  
18 g, and then weights the costs (column i) by the average remaining life (column h) as  
19 derived in the survivor curve analysis. Similarly, the methodology also applies the TNS  
20 rates (column f) to the terminal retirements (column d) to develop terminal retirement  
21 costs (column j) and then weights those costs (column l) by the economic lifespan  
22 (column k).

23 In part C, the methodology composites the interim and terminal retirement costs  
24 to develop the average remaining years for recovery of negative salvage costs (column h).

1 The total salvage costs, as estimated by the TNS study (sum of column e) are then  
2 divided by the remaining years for an annual negative salvage recovery amount (column  
3 g). That amount is then divided by the gross plant in service (column b) to arrive at the  
4 composite negative salvage rate (boxed figure in Column h). I developed the negative  
5 salvage rate recommendations for ANR by compositing the estimated cost of retiring  
6 interim plant retirements and the estimated cost of retiring all the remaining plant at the  
7 economic termination date. I relied on ANR witness Taylor's TNS study for the  
8 estimated cost to dismantle and remove the ANR facilities. Using the TNS as a  
9 foundation I calculated negative salvage rates by FERC property account (Column e of  
10 Schedule No. 6 for Storage Plant and Schedule No. 7 for Transmission Plant, in Exhibit  
11 No. ANR-059. I applied these negative salvage rates to the estimated interim retirements  
12 to arrive at the cost of interim retirements. Then, subtracting the interim retirements from  
13 the total plant in service, I arrived at the plant subject to terminal retirement. I applied  
14 the negative salvage rates to the terminal retirement plant to arrive at the cost of terminal  
15 retirements. Because these retirement costs will be recovered over the average  
16 remaining lives of the assets I weighted the costs by the average remaining lives for each  
17 account – the full 35 years for terminal retirements and slightly shorter average remaining  
18 lives for the interim retirements. The composite rates are reported on each schedule and  
19 on Schedule No. 1. These calculations are shown on Exhibit No. ANR-059, Schedule  
20 No. 6 for Storage plant and Schedule No. 7 for Transmission Plant.

21 **Q. What is the composite negative salvage rate for transmission and storage plant?**

22 A. The composite rate for Storage negative salvage is 0.70%; the composite rate for  
23 Transmission negative salvage is 1.46%.

24 **Q. Does this conclude your Prepared Direct Testimony?**

1 A. Yes, it does.

UNITED STATES OF AMERICA  
BEFORE THE  
FEDERAL ENERGY REGULATORY COMMISSION

ANR Pipeline Company )

Docket No. RP16-\_\_\_\_-000

District of Columbia ) ss.


AFFIDAVIT OF PATRICK R. CROWLEY

Patrick R. Crowley, being first duly sworn, on oath states that he is the witness whose testimony appears on the preceding pages entitled "Prepared Direct Testimony of Patrick R. Crowley"; that, if asked the questions which appear in the text of said testimony, he would give the answers that are therein set forth; and that affiant adopts the aforesaid testimony as Patrick R. Crowley's sworn testimony in this proceeding.

  
\_\_\_\_\_  
Patrick R. Crowley

SWORN TO AND SUBSCRIBED BEFORE ME THIS 26<sup>th</sup> DAY OF January, 2016



  
\_\_\_\_\_  
Notary Public  
My Commission Expires:

STEPHANIE J. WILKERSON  
NOTARY PUBLIC DISTRICT OF COLUMBIA  
My Commission Expires June 30, 2019